

MEMORANDUM

DEPARTMENT OF ENVIRONMENTAL QUALITY
Blue Ridge Regional Office

3019 Peters Creek Road

Roanoke, VA 24019

SUBJECT: Fact Sheet Amendment, Staff Initiated Modification
Town of Floyd-Floyd County Public Service Authority WWTP; VA0025992

TO: Permit File

FROM: Becky L. France, Water Permit Writer *BJF*

DATE: February 6, 2013

Reviewed by: *[Signature]* Date: *2-6-13*

MODIFICATION RATIONALE:

This modification is being initiated to add a quantification level for chlorine to Part I.D.1.a so that the effluent total residual chlorine monthly average and weekly average values are reported complying with DEQ's maximum quantification level requirement for this parameter. A quantification level of 0.10 mg/L has been added to this special condition.

In accordance with 9 VAC 25-3-400A of the VPDES Permit Regulation, correction of this technical error is allowed as a minor modification. So, a public notice is not required.

Backsliding Review

There are no changes in any permit limits, so backsliding is not an issue

Antidegradation Review

Since there are no increases in pollutants, there are no antidegradation issues.